

TEST REPORT FIRES-FR-030-13-AUNE

**Cable bearing system and fireboxes BAKS with cables business
Zakłady Kablowe BITNER Celina Bitner**

This is an electronic version of a test report which was made as a copy of test report officially issued in a paper form. The electronic version of a test report shall be used only for informative purposes. Any information listed in this test report is the property of the sponsor and shall not be used or published without written permission. Contents of this file may only be modified by the editor i.e. Testing laboratory FIRES s.r.o. Batizovce. Sponsor is allowed to publish this test report in parts only with written permission of the editor.



TEST REPORT

FIRES-FR-030-13-AUNE

Tested property: Function in fire
Test method: STN 92 0205: 2012 (ZP-27/2008, DIN 4102-12: 1998-11)
Date of issue: 28. 02. 2013

Name of the product: Cable bearing system and fireboxes BAKS with cables business
Zakłady Kablowe BITNER Celina Bitner

Manufacturer: BAKS Kazimierz Sielski, ul. Jagodne 5, 05 - 480 Karczew,
Poland - producer of construction

Zakłady Kablowe BITNER Celina Bitner, ul. Friedleina 3/3,
30-009 Kraków, Poland – producer of cables

Sponsor: BAKS Kazimierz Sielski, ul. Jagodne 5, 05-480 Karczew, Poland

Task No.: PR-13-0066
Specimens received: 25. 02. 2013
Date of the test: 28. 02. 2013

Technician responsible for the technical side of this report: Bc. Dávid Šubert

Number of pages: 76
Test reports: 5

Copy No.: 2

Distribution list:

- Copy No. 1 FIRES, s. r. o., Osloboditeľov 282, 059 35 Batizovce, Slovak Republic (electronic version)
- Copy No. 2 BAKS Kazimierz Sielski, ul. Jagodne 5, 05 - 480 Karczew, Poland (electronic version)
- Copy No. 3 Zakłady Kablowe BITNER Celina Bitner, ul. Friedleina 3/3, 30-009 Kraków, Poland (electronic version)
- Copy No. 4 BAKS Kazimierz Sielski, ul. Jagodne 5, 05-480 Karczew, Poland
- Copy No. 5 Zakłady Kablowe BITNER Celina Bitner, ul. Friedleina 3/3, 30-009 Kraków, Poland

This report includes accreditation mark SNAS with additional mark ILAC-MRA. SNAS is signatory of ILAC-MRA, Mutual recognition agreement (of accreditation), which is focused on promoting of international acceptance of accredited laboratory data and reducing technical barriers to trade, such as the retesting of products on markets of signatories. More information about ILAC-MRA is on www.ilac.org. Signatories of ILAC-MRA are e.g. SNAS (Slovakia), CAI (Czech Republic), PCA (Poland), DakS (Germany) or BMWA (Austria). Up to date list of ILAC-MRA signatories is on www.ilac.org/documents/mra_signatories.pdf. FIRES, s.r.o. Batizovce is full member of EGOLF also, more information www.egolf.org.uk.



1. INTRODUCTION

This test report contains the results of test carried out by laboratory of FIRES, s.r.o. in Batizovce, accredited by SNAS for testing. Certificate of accreditation No.: S-159. The purpose of the test was to gain information for product classification.

Test of function in fire was carried out according to standard STN 92 0205: 2012. Similar standards and regulations for tests of function in fire are ZP-27/2008 PAVUS and DIN 4102-12: 1998-11.

Deviations from standard at the test according to ZP-27/2008: This test was carried out according to standard STN 92 0205: 2012 and meets also all requirements of ZP-27/2008 and test results can be directly used for classification of tested cables according to ZP-27/2008. There are no deviations identified in process and carrying out of test.

Deviations from standard at the test according to DIN 4102-12: 1998-11: This test was carried out according to standard STN 92 0205: 2012 and meets requirements of DIN 4102-12: 1998-11. Basic deviation in process and carrying out of test between these standards is in measuring and in control of temperature in the test furnace. According to STN 92 0205: 2012, plate thermometers according to EN 1363-1: 1999 are used. According to DIN 4102-12: 1998-11, common thermocouples of construction which was used for this measurement till issue of EN 1363-1:1999 are used. Measurement by plate thermometers acc. to EN 1363-1: 1999 can be considered as stricter method of temperature control in test furnace in compare with thermocouples used till issue of EN 1363-1: 1999. Therefore, it is possible to use results of test according to STN 92 025: 2012 for classification of tested cables according to DIN 4102-12: 1998-11, but not conversely. Identified deviation results in stricter course of test and it can lead to reduced classification of tested cables what is accepted as enhanced security in practice.

Representatives from the sponsor's side witnessing the test:

Mr. Jacek Kliczek	BAKS Kazimierz Sielski
Mr. Artur Mucha	BAKS Kazimierz Sielski
Mr. Jerzy Kowalski	BAKS Kazimierz Sielski
Mr. Marcin Tokaj	Zakłady Kablowe BITNER Celina Bitner
Mr. Tomasz Latacz	Zakłady Kablowe BITNER Celina Bitner
Mr. Dominik Palka	Zakłady Kablowe BITNER Celina Bitner

test directed by	Ing. Marek Gorlický
test carried out by	Bc. Dávid Šubert
operator	Miroslav Hudák

2. MEASURING EQUIPMENT

Identification number	Measuring equipment	Note
F 90 004	Vertical test furnace for fire resistance testing	-
F 69 010	PLC system for data acquisition and control TECOMAT TC 700	-
F 40 017	Control and communication software to PLC TECOMAT TC 700	-
F 40 018	SW Reliance	-
F 40 019	Visual and calculating software to PLC TECOMAT TC 700	-
F 40 020	Driver Tecomat – Reliance (SW)	-
F 69 009	PLC system for data acquisition and climate control TECOMAT TC 604	-
F 60 001 - F 60 009	Sensors of temperature and relative air humidity	climatic conditions measuring
F 71 008, F 71 009	Transducer of differential pressure (-50 to + 150) Pa	pressure inside the test furnace



Identification number	Measuring equipment	Note
F 10 521 - F 10 528	Plate thermometers	temperature inside the test furnace, according to EN 1363-1
F 10 701	Sheathed thermocouple type K Ø 3 mm	ambient temperature
F 54 020	Digital calliper (0 to 200) mm	-
F 54 059	Racking meter	-
F 57 007	Digital stop-watch	-
F 96 015	Test signal panel	-

3. PREPARATION OF THE SPECIMENS

Testing laboratory didn't take off individual components of the specimens. Components take-off and its delivering to the testing laboratory were carried out by the test sponsor. Assembling of the supporting system into the test furnace and mounting of cables and weights into the supporting system was carried out by workers of BAKS Kazimierz Sielski and Zakłady Kablowe BITNER Celina Bitner under supervision of laboratory technician.

4. PREPARATION OF THE TEST

4.1 DESCRIPTION OF THE SPECIMENS STRUCTURE

Test specimen comprised from cable bearing system BAKS Kazimierz Sielski company – cable trays, cable mesh trays, cable clips and fireboxes with accessories (consoles, supports, hangers etc.) and power and communication halogen free cables of Zakłady Kablowe BITNER Celina Bitner company.

Cables

Used cables by test:	NHXH 4x1,5RE FE180/E90 0,6/1kV	(6x)
	NHXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV	(4x)
	NHXH 4x50RM FE180/E90 0,6/1kV	(6x)
	NHXCH 4x50RM/25 FE180/E90 0,6/1kV	(4x)
	(N)HXH 4x1,5RE FE180/E90 0,6/1kV	(14x)
	(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV	(10x)
	(N)HXH 4x50RM FE180/E90 0,6/1kV	(10x)
	(N)HXCH 4x50RM/25 FE180/E90 0,6/1kV	(6x)
	(N)HXH 4x6RE FE180/E90 0,6/1kV	(2x)
	HTKSH 1x2x0,8 FE180/PH90/E90 225V	(14x)
	HTKSHekw 1x2x0,8 FE180/PH90/E90 225V	(8x)
	HDGs 2x1,0 FE180/PH90/E90 300/500V	(12x)
	HDGsekwf 2x1,0 FE180/PH90/E90 300/500V	(10x)
	BiTflame AS 1x2x0,8 FE180/PH90/E90 225V	(2x)
	BiTflame AS(St) 1x2x0,8 FE180/PH90/E90 225V	(2x)
	BiTflame S 2x1,0 FE180/PH90/E90 300/500V	(2x)
	BiTflame S(St) 2x1,0 FE180/PH90/E90 300/500V	(2x)
	JE-H(St)H 2x2x0,8 FE180/E90	(2x)

The length of cables was 4,5 m, 3 m from that was exposed to fire.

Power and communication halogen free cables were fixed in the ladders and mesh trays by steel clips in the points of allowed bending radius.

Power and communication halogen free cables were not fixed in the trays in the points of allowed bending radius.



Cable bearing systems were made of following constructions:

Suspension tracks No. 1 and 2

Tracks are made of three consoles (WPC/WPCO1000) which are fixed to ceiling by two threaded rods (PG M10) in spacing of 1500 mm. Two brackets (WMC/WMCO400) are fixed to consoles by screws (SM M10x30). Holders (UPW/UPWO) are fixed at the end of brackets with screws (SGN M8x14). Brackets are fixed through these holders by threaded rods (PG M10) with washer and nuts (M10) to ceiling holders (USV/USOV).

Tracks No. 1 and 2:

Cable trays (KGL/KGOL300H60/B-300, steel sheet thickness 0,7 mm) fixed together by screws (SGN M6x12). Trays are fixed to supports by screws (SGN M6x12) and loaded with 20kg.m^{-1} .

Suspension tracks No. 3 and 4

Tracks are made of three consoles (WPC/WPCO1000) which were fixed to ceiling by two threaded rods (PG M10) in spacing of 1500 mm. Two brackets (WMC/WMCO400) were fixed to consoles by screws (SM M10x30). Holders (UPW/UPWO) were fixed at the end of brackets with screws (SGN M8x14). Brackets were fixed through these holders by threaded rods (PG M10) with washer and nuts (M10) to ceiling holders (USV/USOV).

Tracks No. 3 and 4:

Cable trays (KGJ/KGOJ400H60/B-400, steel sheet thickness 0,9 mm) fixed together by screws (SGN M6x12). Trays are fixed to supports by screws (SGN M6x12) and loaded with 20kg.m^{-1} .

Suspension tracks No. 5 and 6

Tracks are made of three consoles combined of two horizontal supports (CWP/CWOP40H40/05) and two threaded rods (PG M10) fixed to trapezoidal steel sheets by hangers (WT/WTO120) and threaded rods (PG M8) in spacing of 1500 mm.

Tracks No. 5 and 6:

Cable mesh trays (KDS/KDSO400H60/B-400, steel wire $\varnothing$ 4,5 mm) fixed together by junctions (USS/USSO). Mesh trays are fixed to supports by junctions (ZS/ZSO) and loaded with 20kg.m^{-1} . Cables at mesh trays are fixed by cable clips (UKZ/UKZO1).

Suspension tracks No. 7 - 10

Tracks are made of three consoles combined of two horizontal supports (CWP/CWOP40H40/05) and two threaded rods (PG M10) fixed through the ceiling in spacing of 1500 mm.

Tracks No. 7 and 8:

Cable trays (KGL/KGOL300H60/B-300, steel sheet thickness 0,7 mm) fixed together by screws (SGN M6x12). Trays are fixed to supports by screws (SGN M6x12) and loaded with 20kg.m^{-1} .

Tracks No. 9 and 10:

Cable trays (KGJ/KGOJ400H60/B-400, steel sheet thickness 0,9 mm) fixed together by screws (SGN M6x12). Trays are fixed to supports by screws (SGN M6x12) and loaded with 20kg.m^{-1} .

Track No. 11

Supporting construction is made of gypsum boards 12 mm thick fixed to side wall of furnace. Track is made of cable clips (UDF) fixed to gypsum boards by dowels (HM 5x37S) in spacing of 600 mm.

Track No. 12

Track is made of fireboxes (PMO1) and cable clips (KSA) fixed to ceiling in spacing of 300 mm.

Track No. 13

Track is made of fireboxes (PMO2) and cable clips (KSA) fixed to ceiling in spacing of 300 mm.

**Track No. 14**

Track is made of threaded rods (PG M6) fixed to trapezoidal steel sheet by hangers (WT/WTO120) and threaded rods (PG M6) in spacing of 1500 mm.

Cable mesh trays (KDS/KDSO60H60/3, steel wire $\varnothing$ 4,5 mm) fixed together by junctions (USS/USSO). Mesh trays are fixed to threaded rods by hangers (WKS/WKSO60) and loaded with 2kg.m^{-1} .

Track No. 15

Track is made of cable clips (UDF) fixed to side wall of furnace by dowels (FMD 6x32) and (FMD 6x40) in spacing of 600 mm.

All bearing systems were from steel, galvanized according to the Sendzimir method PN-EN 10327:2005.

More detailed information about construction of specimens is shown in the drawings which form an integral part of this test report. Drawings were delivered by sponsor.

All the information about technical specifications of used materials and semi-products, information about their type sign were delivered by sponsor. This information was not subject of the inspection of specimens. Parameters which were checked are quoted in paragraph 4.3.

4.2 DESCRIPTION OF SPECIMENS FIXATION

The test specimens were fixed on the ceiling of the test furnace which was created from aerated concrete panels with dimensions (4000 x 600 x 240) mm – 6 pieces and fixed to side walls made of aerated concrete blocks YTONG, 250 mm thick. Ceiling panels were jointed by beam which provides balance deflection of the ceiling.

The type of specimen's fixation into the test furnace is shown in drawing documentation and it was selected by the sponsor.

4.3 INSPECTION OF SPECIMENS

Before and after the function in fire test, conformity of drawings and test specimens was checked. Specimens corresponded to the drawings which are part of this test report. Inspection of specimens consisted of visual review of the test specimens, used materials as well as size verification (number and cross sections of conductors, thickness, measurements of cables and trays) and also the way of specimens fixation to supporting construction was subject of inspection.

4.4 CLIMATIC CONDITIONING OF SPECIMENS

Test specimens were stored in the hall of testing laboratory under the following climatic conditions:

Ambient air temperature [°C]

mean	19,5
standard deviation	0,6

Relative air humidity [%]

mean	45,6
standard deviation	2,4

The humidity equilibrium state of test specimens was not determined. Test specimens did not comprise hygroscopic materials.



5. CARRYING OUT OF THE TEST

5.1 TEST GENERALLY

The test was carried out in horizontal test furnace with dimensions of (3000 x 3000 x 2750) mm (length x width x height).

5.2 CONDITIONS OF THE TEST

Conditions in the test furnace (temperature – standard temperature/time curve, pressure, content of O₂) as well as in the testing room (ambient temperature) corresponded to EN 1363-1 during the test. Detailed information is part of this test report, or in Quality records of the testing laboratory.

Values characterizing environment in the testing room directly before the test:

Date of the test	Relative air humidity [%]	Ambient air temperature [°C]
28. 02. 2013	42,4	19,6

5.3 RESULTS OF THE TEST

Measured values are stated in this test report.

6. CLOSING

Evaluation of the test:

Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
1	cable (N)HXH 4x50RM FE180/E90 0,6/1kV	11	53 minutes
2	cable (N)HXH 4x50RM FE180/E90 0,6/1kV		90 minutes no failure / interruption
3	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		90 minutes no failure / interruption
4	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		84 minutes
5	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
6	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
7	cable (N)HXCH 4x50RM/25 FE180/E90 0,6/1kV	10	90 minutes no failure / interruption
8	cable (N)HXCH 4x50RM/25 FE180/E90 0,6/1kV		90 minutes no failure / interruption
9	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		61 minutes
10	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		60 minutes
11	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV	9	90 minutes no failure / interruption
12	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
13	cable (N)HXH 4x50RM FE180/E90 0,6/1kV		90 minutes no failure / interruption
14	cable (N)HXH 4x50RM FE180/E90 0,6/1kV		90 minutes no failure / interruption
15	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV + fireboxes PMO2	13	90 minutes no failure / interruption
16	cable NHXCH 4x50RM/25 FE180/E90 0,6/1kV	8	90 minutes no failure / interruption
17	cable NHXCH 4x50RM/25 FE180/E90 0,6/1kV		90 minutes no failure / interruption
18	cable NHXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		90 minutes no failure / interruption
19	cable NHXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		90 minutes no failure / interruption
20	cable NHXH 4x50RM FE180/E90 0,6/1kV	7	90 minutes no failure / interruption
21	cable NHXH 4x50RM FE180/E90 0,6/1kV		90 minutes no failure / interruption
22	cable NHXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
23	cable NHXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption



Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
24	cable NHXH 4x50RM FE180/E90 0,6/1kV	6	90 minutes no failure / interruption
25	cable NHXH 4x50RM FE180/E90 0,6/1kV		90 minutes no failure / interruption
26	cable NHXH 4x1,5RE FE180/E90 0,6/1kV		88 minutes
27	cable NHXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
28	cable (N)HXH 4x50RM FE180/E90 0,6/1kV	5	31 minutes
29	cable (N)HXH 4x50RM FE180/E90 0,6/1kV		90 minutes no failure / interruption
30	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV		84 minutes
31	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV		89 minutes
32	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV	14	90 minutes no failure / interruption
33	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
34	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		50 minutes
35	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		69 minutes
36	cable (N)HXH 4x6RE FE180/E90 0,6/1kV + fireboxes PMO2	13	90 minutes no failure / interruption
37	cable (N)HXH 4x6RE FE180/E90 0,6/1kV + fireboxes PMO1	12	90 minutes no failure / interruption
38	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV+ fireboxes PMO1		90 minutes no failure / interruption
39	2 cables NHXCH 4x50RM/25 FE180/E90 0,6/1kV	4	90 minutes no failure / interruption
40	2 cables NHXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		90 minutes no failure / interruption
41	2 cables NHXH 4x50RM FE180/E90 0,6/1kV	3	90 minutes no failure / interruption
42	2 cables NHXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
43	2 cables (N)HXCH 4x50RM/25 FE180/E90 0,6/1kV	2	90 minutes no failure / interruption
44	2 cables (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		67 minutes
45	2 cables (N)HXH 4x50RM FE180/E90 0,6/1kV	1	90 minutes no failure / interruption
46	2 cables (N)HXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
47	2 cables (N)HXCH 4x50RM/25 FE180/E90 0,6/1kV	15	85 minutes
48	2 cables (N)HXH 4x50RM FE180/E90 0,6/1kV		63 minutes
49	2 cables (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		68 minutes
50	2 cables (N)HXH 4x1,5RE FE180/E90 0,6/1kV		90 minutes no failure / interruption
52A	2 cables HTKSHekw 1x2x0,8 FE180/PH90/E90 225V	11	73 minutes
52B	2 cables HDGsekwf 2x1,0 FE180/PH90/E90 300/500V		90 minutes no failure / interruption
53A	2 cables BiTflame S(St) 2x1,0 FE180/PH90/E90 300/500V	10	90 minutes no failure / interruption
53B	2 cables HDGsekwf 2x1,0 FE180/PH90/E90 300/500V		90 minutes no failure / interruption
54A	2 cables BiTflame S 2x1,0 FE180/PH90/E90 300/500V	9	90 minutes no failure / interruption
54B	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V		90 minutes no failure / interruption
55	cable JE-H(St)H 2x2x0,8 FE180/E90 225V + fireboxes PMO2	13	90 minutes no failure / interruption
56	cable HTKSH 1x2x0,8 FE180/E90 225V + fireboxes PMO2		90 minutes no failure / interruption
57	2 cables HTKSHekw 1x2x0,8 FE180/PH90/E90 225V	8	77 minutes
58	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V	7	51 minutes
59A	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V - test	16	90 minutes no failure / interruption
59B	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V - test		6 minutes
60A	2 cables HTKSHekw 1x2x0,8 FE180/PH90/E90 225V	6	90 minutes no failure / interruption
60B	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V		90 minutes no failure / interruption
61A	2 cables HDGsekwf 2x1,0 FE180/PH90/E90 300/500V	5	90 minutes no failure / interruption
61B	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V		57 minutes
62	2 cables HDGsekwf 2x1,0 FE180/PH90/E90 300/500V	14	36 minutes
63	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V		90 minutes no failure / interruption
64	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V		90 minutes no failure / interruption



Specimen No.	Cables	Track No.	Time to first failure / interruption of conductor
65	2 cables BiTflame AS(St) 1x2x0,8 FE180/PH90/E90 225V	4	73 minutes
66	2 cables HTKSHekw 1x2x0,8 FE180/PH90/E90 225V		88 minutes
67	2 cables BiTflame AS 1x2x0,8 FE180/PH90/E90 225V	3	90 minutes no failure / interruption
68	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V		41 minutes
69	2 cables HDGsekwf 2x1,0 FE180/PH90/E90 300/500V	2	68 minutes
70	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V	1	90 minutes no failure / interruption
71	cable JE-H(St)H 2x2x0,8 FE180/E90 225V + fireboxes PMO1	12	90 minutes no failure / interruption
72	cable HTKSH 1x2x0,8 FE180/E90 225V + fireboxes PMO1		90 minutes no failure / interruption
73	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V	15	90 minutes no failure / interruption
74	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V		90 minutes no failure / interruption

The fire test was discontinued in 94th minute at the request of test sponsor.

Specimens S1 – S50 were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.
 Specimens S52 – S74 were tested by one-phase voltage supply 1 x 110V with LED diodes 3V / 0,03W.
 Circuit breakers with rating 3 A were used.




Measured values inside the test furnace

Time t [min]	Temperature [°C]											Deviation d _e [%]	Pressure p [Pa]
	Td1	Td2	Td3	Td4	Td5	Td6	Td7	Td8	Tave	Tn	To		
0	20,4	19,0	18,3	20,8	21,3	22,1	21,7	21,7	20,7	20,0	19,6	0,0	20,0
5	598,8	601,0	578,0	616,6	556,2	525,1	596,6	580,0	581,5	576,0	18,5	-2,1	17,6
10	702,8	695,6	664,4	700,1	708,9	702,8	710,0	678,7	695,4	678,0	17,6	0,1	18,8
15	757,5	743,5	722,0	756,9	766,4	764,7	771,5	748,1	753,8	739,0	18,5	0,6	19,3
20	795,4	779,7	755,3	788,7	803,5	805,5	811,1	781,4	790,1	781,0	17,9	0,9	18,1
25	824,3	807,9	786,2	821,6	831,6	837,1	840,6	810,5	820,0	815,0	19,3	0,8	19,3
30	851,0	834,6	812,1	850,8	854,6	859,4	867,4	839,1	846,1	842,0	19,0	0,8	19,3
35	873,0	868,0	839,8	868,3	869,5	869,1	877,9	856,8	865,3	865,0	18,7	0,7	17,3
40	905,3	908,0	880,1	897,8	893,0	888,1	902,6	875,0	893,7	885,0	18,9	0,7	19,2
45	899,7	900,3	901,2	901,0	903,5	898,6	899,0	901,2	900,6	902,0	19,0	0,7	19,5
50	888,8	882,3	881,9	902,3	888,6	885,0	895,2	902,8	890,9	918,0	18,2	0,3	19,8
55	913,9	907,9	902,3	918,2	913,1	909,5	919,9	919,2	913,0	932,0	18,7	0,0	17,6
60	940,7	937,7	950,7	952,0	931,4	922,4	943,6	950,8	941,2	945,0	18,5	-0,1	17,0
65	957,8	955,7	968,6	972,4	949,1	940,4	959,8	968,9	959,1	957,0	19,2	-0,1	18,2
70	972,7	970,4	982,8	991,0	963,4	957,1	974,9	982,3	974,3	968,0	18,4	0,0	18,1
75	983,4	979,4	988,3	999,5	986,9	969,1	987,3	994,4	986,0	979,0	18,8	0,0	17,4
80	994,3	990,0	996,8	1009,8	987,4	980,6	998,5	1004,7	995,3	988,0	18,8	0,1	19,1
85	1004,5	1000,4	1008,4	1019,2	997,8	991,4	1008,6	1013,8	1005,5	997,0	19,0	0,1	18,7
90	1014,6	1010,5	1016,8	1028,9	1007,8	1002,0	1018,6	1023,1	1015,3	1006,0	19,4	0,2	17,7
91	1017,1	1013,3	1020,2	1032,6	1010,1	1003,9	1020,8	1026,9	1018,1	1008,0	19,4	0,2	18,9
92	1018,4	1014,6	1024,0	1034,0	1011,8	1005,5	1022,2	1027,5	1019,8	1009,0	18,0	0,2	19,9
93	1020,4	1017,2	1020,6	1034,6	1011,7	1005,7	1023,5	1027,0	1020,1	1011,0	19,4	0,2	17,9




- Tave** Average temperature in the test furnace calculated from plate thermometers
- Tn** Standard temperature in the test furnace laid down to test guideline
- To** Ambient temperature
- d_e** Deviation of the average temperature from the standard temperature calculated according to test guideline
- p** Pressure inside the test furnace measured under the ceiling of the test furnace

Layout of measuring points inside the test furnace:





Measured values inside the test furnace /graph




Measured time of tested specimens from S1 to S10 - power cables

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S1	1-L1	x
	2-L2	53:57
	3-L3	53:57
	4-PEN	x
S2	5-L1	no failure / interruption
	6-L2	no failure / interruption
	7-L3	no failure / interruption
	8-PEN	no failure / interruption
S3	9-L1	no failure / interruption
	10-L2	no failure / interruption
	11-L3	no failure / interruption
	12-PEN	no failure / interruption
S4	13-L1	84:44
	14-L2	84:44
	15-L3	84:44
	16-PEN	x
S5	17-L1	no failure / interruption
	18-L2	no failure / interruption
	19-L3	no failure / interruption
	20-PEN	no failure / interruption
S6	21-L1	no failure / interruption
	22-L2	no failure / interruption
	23-L3	no failure / interruption
	24-PEN	no failure / interruption
S7	25-L1	no failure / interruption
	26-L2	no failure / interruption
	27-L3	no failure / interruption
	28-PEN	no failure / interruption
S8	29-L1	no failure / interruption
	30-L2	no failure / interruption
	31-L3	no failure / interruption
	32-PEN	no failure / interruption
S9	33-L1	61:06
	34-L2	61:06
	35-L3	61:06
	36-PEN	x
S10	37-L1	60:05
	38-L2	60:05
	39-L3	60:05
	40-PEN	x

Specimen No.	Cables
1	cable (N)HXH 4x50RM FE180/E90 0,6/1kV
2	cable (N)HXH 4x50RM FE180/E90 0,6/1kV
3	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
4	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
5	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV
6	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV
7	cable (N)HXCH 4x50RM/25 FE180/E90 0,6/1kV
8	cable (N)HXCH 4x50RM/25 FE180/E90 0,6/1kV
9	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
10	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV

- x Conductor was turned off manually after permanent interruption / failure of other conductors in the cable
 Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.
 Circuit breakers with rating 3 A were used.


Measured time of tested specimens from S11 to S20 - power cables

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S11	41-L1	no failure / interruption
	42-L2	no failure / interruption
	43-L3	no failure / interruption
	44-PEN	no failure / interruption
S12	45-L1	no failure / interruption
	46-L2	no failure / interruption
	47-L3	no failure / interruption
	48-PEN	no failure / interruption
S13	49-L1	no failure / interruption
	50-L2	no failure / interruption
	51-L3	no failure / interruption
	52-PEN	no failure / interruption
S14	53-L1	no failure / interruption
	54-L2	no failure / interruption
	55-L3	no failure / interruption
	56-PEN	no failure / interruption
S15	57-L1	no failure / interruption
	58-L2	no failure / interruption
	59-L3	no failure / interruption
	60-PEN	no failure / interruption
S16	61-L1	no failure / interruption
	62-L2	no failure / interruption
	63-L3	no failure / interruption
	64-PEN	no failure / interruption
S17	65-L1	no failure / interruption
	66-L2	no failure / interruption
	67-L3	no failure / interruption
	68-PEN	no failure / interruption
S18	69-L1	no failure / interruption
	70-L2	no failure / interruption
	71-L3	no failure / interruption
	72-PEN	no failure / interruption
S19	73-L1	no failure / interruption
	74-L2	no failure / interruption
	75-L3	no failure / interruption
	76-PEN	no failure / interruption
S20	77-L1	no failure / interruption
	78-L2	no failure / interruption
	79-L3	no failure / interruption
	80-PEN	no failure / interruption

Specimen No.	Cables
11	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV
12	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV
13	cable (N)HXH 4x50RM FE180/E90 0,6/1kV
14	cable (N)HXH 4x50RM FE180/E90 0,6/1kV
15	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV + fireboxes PMO2
16	cable NHXCH 4x50RM/25 FE180/E90 0,6/1kV
17	cable NHXCH 4x50RM/25 FE180/E90 0,6/1kV
18	cable NHXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
19	cable NHXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
20	cable NHXH 4x50RM FE180/E90 0,6/1kV

Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.
Circuit breakers with rating 3 A were used.


Measured time of tested specimens from S21 to S30 - power cables

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S21	81-L1	no failure / interruption
	82-L2	no failure / interruption
	83-L3	no failure / interruption
	84-PEN	no failure / interruption
S22	85-L1	no failure / interruption
	86-L2	no failure / interruption
	87-L3	no failure / interruption
	88-PEN	no failure / interruption
S23	89-L1	no failure / interruption
	90-L2	no failure / interruption
	91-L3	no failure / interruption
	92-PEN	no failure / interruption
S24	93-L1	no failure / interruption
	94-L2	no failure / interruption
	95-L3	no failure / interruption
	96-PEN	no failure / interruption
S25	97-L1	no failure / interruption
	98-L2	no failure / interruption
	99-L3	no failure / interruption
	100-PEN	no failure / interruption
S26	101-L1	88:09
	102-L2	x
	103-L3	x
	104-PEN	x
S27	105-L1	no failure / interruption
	106-L2	no failure / interruption
	107-L3	no failure / interruption
	108-PEN	no failure / interruption
S28	109-L1	x
	110-L2	x
	111-L3	31:26
	112-PEN	x
S29	113-L1	no failure / interruption
	114-L2	no failure / interruption
	115-L3	no failure / interruption
	116-PEN	no failure / interruption
S30	117-L1	x
	118-L2	x
	119-L3	84:54
	120-PEN	x

Specimen No.	Cables
21	cable NHXH 4x50RM FE180/E90 0,6/1kV
22	cable NHXH 4x1,5RE FE180/E90 0,6/1kV
23	cable NHXH 4x1,5RE FE180/E90 0,6/1kV
24	cable NHXH 4x50RM FE180/E90 0,6/1kV
25	cable NHXH 4x50RM FE180/E90 0,6/1kV
26	cable NHXH 4x1,5RE FE180/E90 0,6/1kV
27	cable NHXH 4x1,5RE FE180/E90 0,6/1kV
28	cable (N)HXH 4x50RM FE180/E90 0,6/1kV
29	cable (N)HXH 4x50RM FE180/E90 0,6/1kV
30	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV

- x Conductor was turned off manually after permanent interruption / failure of other conductors in the cable
 Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.
 Circuit breakers with rating 3 A were used.


Measured time of tested specimens from S31 to S40 - power cables

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S31	121-L1	x
	122-L2	x
	123-L3	89:46
	124-PEN	x
S32	125-L1	no failure / interruption
	126-L2	no failure / interruption
	127-L3	no failure / interruption
	128-PEN	no failure / interruption
S33	129-L1	no failure / interruption
	130-L2	no failure / interruption
	131-L3	no failure / interruption
	132-PEN	no failure / interruption
S34	133-L1	x
	134-L2	x
	135-L3	50:24
	136-PEN	x
S35	137-L1	69:02
	138-L2	69:02
	139-L3	69:02
	140-PEN	x
S36	141-L1	no failure / interruption
	142-L2	no failure / interruption
	143-L3	no failure / interruption
	144-PEN	no failure / interruption
S37	145-L1	no failure / interruption
	146-L2	no failure / interruption
	147-L3	no failure / interruption
	148-PEN	no failure / interruption
S38	149-L1	no failure / interruption
	150-L2	no failure / interruption
	151-L3	no failure / interruption
	152-PEN	no failure / interruption
S39	153-L1	no failure / interruption
	154-L2	no failure / interruption
	155-L3	no failure / interruption
	156-PEN	no failure / interruption
S40	157-L1	no failure / interruption
	158-L2	no failure / interruption
	159-L3	no failure / interruption
	160-PEN	no failure / interruption

Specimen No.	Cables
31	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV
32	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV
33	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV
34	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
35	cable (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
36	cable (N)HXH 4x6RE FE180/E90 0,6/1kV + fireboxes PMO2
37	cable (N)HXH 4x6RE FE180/E90 0,6/1kV + fireboxes PMO1
38	cable (N)HXH 4x1,5RE FE180/E90 0,6/1kV+ fireboxes PMO1
39	2 cables NHXCH 4x50RM/25 FE180/E90 0,6/1kV
40	2 cables NHXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV

- x Conductor was turned off manually after permanent interruption / failure of other conductors in the cable
 Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.
 Circuit breakers with rating 3 A were used.


Measured time of tested specimens from S41 to S50 - power cables

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S41	161-L1	no failure / interruption
	162-L2	no failure / interruption
	163-L3	no failure / interruption
	164-PEN	no failure / interruption
S42	165-L1	no failure / interruption
	166-L2	no failure / interruption
	167-L3	no failure / interruption
	168-PEN	no failure / interruption
S43	169-L1	no failure / interruption
	170-L2	no failure / interruption
	171-L3	no failure / interruption
	172-PEN	no failure / interruption
S44	173-L1	67:45
	174-L2	67:45
	175-L3	67:45
	176-PEN	x
S45	177-L1	no failure / interruption
	178-L2	no failure / interruption
	179-L3	no failure / interruption
	180-PEN	no failure / interruption
S46	181-L1	no failure / interruption
	182-L2	no failure / interruption
	183-L3	no failure / interruption
	184-PEN	no failure / interruption
S47	185-L1	x
	186-L2	85:40
	187-L3	x
	188-PEN	x
S48	189-L1	63:31
	190-L2	63:31
	191-L3	63:31
	192-PEN	x
S49	193-L1	68:47
	194-L2	68:47
	195-L3	x
	196-PEN	x
S50	197-L1	no failure / interruption
	198-L2	no failure / interruption
	199-L3	no failure / interruption
	200-PEN	no failure / interruption

Specimen No.	Cables
41	2 cables NHXH 4x50RM FE180/E90 0,6/1kV
42	2 cables NHXH 4x1,5RE FE180/E90 0,6/1kV
43	2 cables (N)HXCH 4x50RM/25 FE180/E90 0,6/1kV
44	2 cables (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
45	2 cables (N)HXH 4x50RM FE180/E90 0,6/1kV
46	2 cables (N)HXH 4x1,5RE FE180/E90 0,6/1kV
47	2 cables (N)HXCH 4x50RM/25 FE180/E90 0,6/1kV
48	2 cables (N)HXH 4x50RM FE180/E90 0,6/1kV
49	2 cables (N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV
50	2 cables (N)HXH 4x1,5RE FE180/E90 0,6/1kV

- x Conductor was turned off manually after permanent interruption / failure of other conductors in the cable
 Power cables were tested by three-phase voltage supply 3 x 230/400V with bulbs 240V / 60 W.
 Circuit breakers with rating 3 A were used.


Measured time of tested specimen S52 to S61 - communication cables

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S52A	209-L	73:47
	210-PEN	x
S52B	211-L	no failure / interruption
	212-PEN	no failure / interruption
S53A	213-L	no failure / interruption
	214-PEN	no failure / interruption
S53B	215-L	no failure / interruption
	216-PEN	no failure / interruption
S54A	217-L	no failure / interruption
	218-PEN	no failure / interruption
S54B	219-L	no failure / interruption
	220-PEN	no failure / interruption
S55	221-L	no failure / interruption
	222-PEN	no failure / interruption
	223-L	no failure / interruption
	224-PEN	no failure / interruption
S56A	225-L	no failure / interruption
	226-PEN	no failure / interruption
S56B	227-L	no failure / interruption
	228-PEN	no failure / interruption
S57A	229-L	77:49
	230-PEN	x
S57B	231-L	77:50
	232-PEN	x
S58A	233-L	51:18
	234-PEN	x
S58B	235-L	52:41
	236-PEN	x
S59A	237-L	no failure / interruption
	238-PEN	no failure / interruption
S59B	239-L	06:06
	240-PEN	x
S60A	241-L	no failure / interruption
	242-PEN	no failure / interruption
S60B	243-L	no failure / interruption
	244-PEN	no failure / interruption
S61A	245-L	no failure / interruption
	246-PEN	no failure / interruption
S61B	247-L	57:13
	248-PEN	x

Specimen No.	Cables
52A, 57, 60A	2 cables HTKSHekw 1x2x0,8 FE180/PH90/E90 225V
52B, 61A	2 cables HDGsekwf 2x1,0 FE180/PH90/E90 300/500V
53A	2 cables Bitflame S(St) 2x1,0 FE180/PH90/E90 300/500V
53B	2 cables HDGsekwf 2x1,0 FE180/PH90/E90 300/500V
54A	2 cables Bitflame S 2x1,0 FE180/PH90/E90 300/500V
54B, 59A, 61B	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V
55	cable JE-H(St)H 2x2x0,8 FE180/E90 225V + fireboxes PMO2
56	cable HTKSH 1x2x0,8 FE180/E90 225V + fireboxes PMO2
58, 59B, 60B	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V

- x Conductor was turned off manually after permanent interruption / failure of other conductors in the cable
Signal cables were tested by three-phase voltage supply 1 x 110V with LED diodes 3V / 0,03W.
Circuit breakers with rating 3 A were used.


Measured time of tested specimens from S62 to S71 - communication cables

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S62A	249-L	no failure / interruption
	250-PEN	no failure / interruption
S62B	251-L	36:58
	252-PEN	x
S63A	253-L	no failure / interruption
	254-PEN	no failure / interruption
S63B	255-L	no failure / interruption
	256-PEN	no failure / interruption
S64A	257-L	no failure / interruption
	258-PEN	no failure / interruption
S64B	259-L	no failure / interruption
	260-PEN	no failure / interruption
S65A	261-L	no failure / interruption
	262-PEN	no failure / interruption
S65B	263-L	73:21
	264-PEN	x
S66A	265-L	88:53
	266-PEN	x
S66B	267-L	no failure / interruption
	268-PEN	no failure / interruption
S67A	269-L	no failure / interruption
	270-PEN	no failure / interruption
S67B	271-L	no failure / interruption
	272-PEN	no failure / interruption
S68A	273-L	42:18
	274-PEN	x
S68B	275-L	41:38
	276-PEN	x
S69A	277-L	no failure / interruption
	278-PEN	no failure / interruption
S69B	279-L	68:28
	280-PEN	x
S70A	281-L	no failure / interruption
	282-PEN	no failure / interruption
S70B	283-L	no failure / interruption
	284-PEN	no failure / interruption
S71	285-L	no failure / interruption
	286-PEN	no failure / interruption
	287-L	no failure / interruption
	288-PEN	no failure / interruption

Specimen No.	Cables
62	2 cables HDGsekfw 2x1,0 FE180/PH90/E90 300/500V
63	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V
64	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V
65	2 cables BiTflame AS(St) 1x2x0,8 FE180/PH90/E90 225V
66	2 cables HTKSHekw 1x2x0,8 FE180/PH90/E90 225V
67	2 cables BiTflame AS 1x2x0,8 FE180/PH90/E90 225V
68	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V
69	2 cables HDGsekfw 2x1,0 FE180/PH90/E90 300/500V
70	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V
71	cable JE-H(St)H 2x2x0,8 FE180/E90 225V + fireboxes PMO1

- x Conductor was turned off manually after permanent interruption / failure of other conductors in the cable
Signal cables were tested by three-phase voltage supply 1 x 110V with LED diodes 3V / 0,03W.
Circuit breakers with rating 3 A were used.


Measured time of tested specimens S72 to S74 - communication cables

Specimen	Bulbs	Time to permanent failure / interruption [min:s]
S72A	289-L	no failure / interruption
	290-PEN	no failure / interruption
S72B	291-L	no failure / interruption
	292-PEN	no failure / interruption
S73A	293-L	no failure / interruption
	294-PEN	no failure / interruption
S73B	295-L	no failure / interruption
	296-PEN	no failure / interruption
S74A	297-L	no failure / interruption
	298-PEN	no failure / interruption
S74B	299-L	no failure / interruption
	300-PEN	no failure / interruption

Specimen No.	Cables
72	cable HTKSH 1x2x0,8 FE180/E90 225V + fireboxes PMO1
73	2 cables HDGs 2x1,0 FE180/PH90/E90 300/500V
74	2 cables HTKSH 1x2x0,8 FE180/PH90/E90 225V

Signal cables were tested by three-phase voltage supply 1 x 110V with LED diods 3V / 0,03W.
Circuit breakers with rating 3 A were used.



PHOTOS



Photo taken before the test.



Photo taken before the test.



Photo taken before the test.



PHOTOS




Photo taken before the test.



Photo taken before the test.



Photo taken before the test.



PHOTOS



Photo taken during the test.




Photo taken during the test.



Photo taken during the test.



PHOTOS



Photo taken after the test.



Photo taken after the test.



Photo taken after the test.



PHOTOS



Photo taken after the test.




Photo taken after the test.



Photo taken after the test.



CABLES

(N)HXH FE180/E90**FIRE RESISTANT HALOGEN FREE POWER CABLES****APPLICATIONS**

Safety cables are used in all locations where a special protection against fire and fire damage is necessary for human life and equipment and where strict safety regulations have to be met and where large emergency running time is necessary. They may be used indoor and outdoor, but not directly in earth and water. They are considered as protectively insulated.

CONSTRUCTION

conductor - bare copper, solid or stranded acc. to DIN VDE 0295

insulation - cross-linked halogen free ceramic forming polymer compound acc. to DIN VDE 0266

filler - flame resistant, halogen free polymer compound

inner sheath - flame resistant, halogen free polymer compound

sheath - flame resistant, halogen free polymer compound acc. to DIN VDE 0276-604

(N)HXH FE180/E90**CHARACTERISTICS**

Conductor cross-section	
Number of conductors	Nominal conductor cross-section
n	mm ²
1 ÷ 5	1,5 ÷ 240
7 ÷ 10	1,5 ÷ 10
10 ÷ 48	1,5 ÷ 2,5


Operating voltage 0,6/1kV
 Voltage test 4000 V, 50 Hz
 Insulation resistivity at 90°C, minimum 10^{12}

Operating temperature range during operation during installation -25°C up to +90°C
 -5°C up to +50°C
 Minimum bending radius
 15 x D single core
 12 x D multi core
 D = outer diameter

Cable combustibility
 Fire resistance E90
 Combustibility tests PN-EN 50226:2006, IEC 60332-3
 Reference standards DIN VDE 0266



CABLES

(N)HXCH FE180/E90**FIRE RESISTANT HALOGEN FREE POWER CABLES****APPLICATIONS**

Safety cables are used in all locations where a special protection against fire and fire damage is necessary for human life and equipment and where strict safety regulations have to be met and where large emergency running time is necessary. They may be used indoor and outdoor, but not directly in earth and water. They are considered as protectively insulated.

CONSTRUCTION

conductor - bare copper, solid or stranded acc. to DIN VDE 0295

insulation - cross-linked halogen free ceramic forming polymer compound acc. to DIN VDE 0266

filler - flame resistant, halogen free polymer compound

inner sheath - flame resistant, halogen free polymer compound

concentric conductor - formed by bare copper wires with counter copper tape

polyester tape

sheath - flame resistant, halogen free polymer compound acc. to DIN VDE 0276-604

(N)HXCH FE180/E90**CHARACTERISTICS**

Conductor cross-section	
Number of conductors	Nominal conductor cross-section
n	mm ²
1 + 4	1,5/1,5 + 240/120
7	1,5/1,5 + 4/4
10 + 30	1,5/2,5 + 2,5/10

Operating voltage 0,6/1 kV
 Voltage test 4000 V, 50 Hz
 Insulation resistivity at 90°C, minimum 10^{12}


Operating temperature range during operation -25°C up to +90°C
 during installation -5°C up to +50°C

Minimum bending radius
 15 x D single core
 12 x D multi core
 D = outer diameter

Cable combustibility
 Fire resistance E90
 Combustibility tests PN-EN 50226:2006, IEC 60332-3
 Reference standards DIN VDE 0266



CABLES

NHXX FE180/E90**FIRE RESISTANT HALOGEN FREE POWER CABLES****APPLICATIONS**

Safety cables are used in all locations where a special protection against fire and fire damage is necessary for human life and equipment and where strict safety regulations have to be met and where large emergency running time is necessary. They may be used indoor and outdoor, but not directly in earth and water. They are considered as protectively insulated.

CONSTRUCTION

conductor - bare copper, solid or stranded acc. to DIN VDE 0295

insulation - mica tape and cross-linked halogen free forming polymer compound acc. to DIN VDE 0266

filler - flame resistant, halogen free polymer compound

inner sheath - flame resistant, halogen free polymer compound

sheath - flame resistant, halogen free polymer compound acc. to DIN VDE 0276-604

NHXX FE180/E90**CHARACTERISTICS**

Conductor cross-section	
Number of conductors	Nominal conductor cross-section
n	mm ²
1 + 5	1,5 + 300
7 + 10	1,5 + 10
10 + 48	1,5 + 2,5

Operating voltage

0,6/1kV

Voltage test

4000 V, 50 Hz

Insulation resistivity at 90°C,
minimum

10¹²

Operating temperature range

during operation
during installation

-25°C up to +90°C
-5°C up to +50°C

Minimum bending radius

15 x D single core
12 x D multi core
D = outer diameter

Cable combustibility

Fire resistance

E90

Combustibility tests


PN-EN 50226:2006, IEC 60332-3

Reference standards

DIN VDE 0266



CABLES

NHXCH FE180/E90**FIRE RESISTANT HALOGEN FREE POWER CABLES****APPLICATIONS**

Safety cables are used in all locations where a special protection against fire and fire damage is necessary for human life and equipment and where strict safety regulations have to be met and where large emergency running time is necessary. They may be used indoor and outdoor, but not directly in earth and water. They are considered as protectively insulated.

CONSTRUCTION

conductor - bare copper, solid or stranded acc. to DIN VDE 0295

insulation - mica tape and cross-linked halogen free forming polymer compound acc. to DIN VDE 0266

filler - flame resistant, halogen free polymer compound

inner sheath - flame resistant, halogen free polymer compound

concentric conductor - formed by bare copper wires with counter copper tape

polyester tape

sheath - flame resistant, halogen free polymer compound acc. to DIN VDE 0276-604

NHXCH FE180/E90**CHARACTERISTICS**

Conductor cross-section	
Number of conductors	Nominal conductor cross-section
n	mm ²
1 + 4	1,5/1,5 + 240/120
7	1,5/1,5 + 4/4
10 + 30	1,5/2,5 + 2,5/10

Operating voltage

0,6/1 kV

Voltage test

4000 V, 50 Hz

Insulation resistivity at 90°C,
minimum

10¹²

Operating temperature range

during operation
during installation

-25°C up to +90°C
-5°C up to +50°C

Minimum bending radius

15 x D single core
12 x D multi core
D = outer diameter

Cable combustibility

Fire resistance

E90

Combustibility tests

PN-EN 50226:2006, IEC 60332-3

Reference standards


DIN VDE 0266



CABLES

BiT flame AS(St) FE180/PH90/E90

FIRE RESISTANT HALOGEN FREE ELECTRONIC AND TELECOMMUNICATIONS CABLE



APPLICATIONS

Safety installations cables are used for the transmission signals and measuring data in control circuits, in locations where a particular protection against fire and fire damage for human life and equipment is necessary. Installation cables are not admissible for power installation purposes and direct burial.

CONSTRUCTION

conductor - bare copper, solid acc. to PN-EN 60228

insulation - mica tape and halogen free forming polymer compound

wrapping - polyester tape

screen - static screen of plastic coated metal foil with a solid, tinned drain wire

sheath - flame resistant, halogen free polymer compound

BiT flame AS(St) FE180/PH90/E90

CHARACTERISTICS

Conductor cross-section	
Number of conductors	Nominal conductor diameter
n	mm
1 x 2 x 20 x 2 x	0,8
1 x 2 x 10 x 2 x	1,0
1 x 2 x 10 x 2 x	1,4
1 x 2 x 10 x 2 x	1,8
1 x 2 x 10 x 2 x	2,3

Operating voltage 225V

Voltage test 1500 V, 50 Hz

core/core 1500 V, 50 Hz

core/screen 1500 V, 50 Hz

Insulation resistivity at 90°C, minimum 10¹¹

Operating temperature range

during operation -25°C up to +70°C

during installation -5°C up to +50°C

Minimum bending radius 10 x D single core
D = outer diameter

Cable combustibility

Fire resistance E90

Combustibility tests PN-EN 50200, PN-EN 50226:2006
IEC 60332-3


Reference standards ZN-CB-25-2005



CABLES

BiT flame AS FE180/PH90/E90

FIRE RESISTANT HALOGEN FREE ELECTRONIC AND TELECOMMUNICATIONS CABLE



APPLICATIONS

Safety installations cables are used for the transmission signals and measuring data in control circuits, in locations where a particular protection against fire and fire damage for human life and equipment is necessary.

Installation cables are not admissible for power installation purposes and direct burial.

CONSTRUCTION

conductor - bare copper, solid acc. to PN-EN 60228

insulation - mica tape and halogen free forming polymer compound

sheath - flame resistant, halogen free polymer compound

BiT flame AS FE180/PH90/E90

CHARACTERISTICS

Conductor cross-section	
Number of conductors	Nominal conductor diameter
n	mm
1 x 2 x 20 x 2 x	0,8
1 x 2 x 10 x 2 x	1,0
1 x 2 x 10 x 2 x	1,4
1 x 2 x 10 x 2 x	1,8
1 x 2 x 10 x 2 x	2,3

Operating voltage 225V
Voltage test 1500 V, 50 Hz
core/core

Insulation resistivity at 90°C,
minimum 10¹¹

Operating temperature range
during operation -25°C up to +70°C
during installation -5°C up to +50°C
Minimum bending radius 10 x D single core
D = outer diameter


Cable combustibility E90
Fire resistance PN-EN 50200, PN-EN 50226:2006
Combustibility tests IEC 60332-3
Reference standards ZN-CB-25-2005



CABLES

BiT flame S(St) FE180/PH90/E90

FIRE RESISTANT HALOGEN FREE POWER AND CONTROL CABLE



APPLICATIONS

Halogen-free fire resistant cables are designed for installation in places where it is necessary to ensure operation of devices under fire conditions. There are recommended for emergency lighting installations, smoke extraction systems, alarm systems, signalling systems, sound warning and control systems, fire alarm signaling and automation and other safety ensuring circuits.

CONSTRUCTION

conductor - bare copper, solid acc. to PN-EN 60228

insulation - cross-linked halogen free ceramic forming polymer compound

wrapping - polyester tape

screen - static screen of plastic coated metal foil with tinned copper drain wire

sheath - flame resistant, halogen free polymer compound

BiT flame S(St) FE180/PH90/E90

CHARACTERISTICS

Conductor cross-section	
Number of conductors	Nominal conductor cross-section
n	mm ²
2 + 5	1 + 10
6 + 37	1 + 2,5

Operating voltage 300/500 V

Voltage test 2000 V, 50 Hz

core/core 2000 V, 50 Hz

core/screen 2000 V, 50 Hz

Insulation resistivity at 90°C,
minimum 10^{11}

Operating temperature range

during operation -25°C up to +70°C

during installation -10°C up to +50°C

Minimum bending radius
10 x D single core
D = outer diameter

Cable combustibility

Fire resistance E90

Combustibility tests PN-EN 50200, PN-EN 50226:2006
IEC 60332-3


Reference standards ZN-CB-03-2002



CABLES

BiT flame S FE180/PH90/E90

FIRE RESISTANT HALOGEN FREE POWER AND CONTROL CABLE



APPLICATIONS

Halogen-free fire resistant cables are designed for installation in places where it is necessary to ensure operation of devices under fire conditions. There are recommended for emergency lighting installations, smoke extraction systems, alarm systems, signalling systems, sound warning and control systems, fire alarm signaling and automation and other safety ensuring circuits.

CONSTRUCTION

conductor - bare copper, solid acc. to PN-EN 60228

insulation - cross-linked halogen free ceramic forming polymer compound

sheath - flame resistant, halogen free polymer compound

BiT flame S FE180/PH90/E90

CHARACTERISTICS

Conductor cross-section	
Number of conductors	Nominal conductor cross-section
n	mm ²
2 + 5	1 + 10
6 + 37	1 + 2,5

Operating voltage 300/500 V
 Voltage test 2000 V, 50 Hz
 core/core 2000 V, 50 Hz
 core/screen 2000 V, 50 Hz

Insulation resistivity at 90°C, minimum 10¹¹

Operating temperature range during operation during installation -25°C up to +70°C
 -10°C up to +50°C
 Minimum bending radius 10 x D single core
 D = outer diameter


Cable combustibility E90
 Fire resistance PN-EN 50200, PN-EN 50226:2006
 Combustibility tests IEC 60332-3
 Reference standards ZN-CB-03-2002



CABLES

HDGs FE180/PH90/E90

FIRE RESISTANT HALOGEN FREE POWER AND CONTROL CABLE



APPLICATIONS

Halogen-free fire resistant cables are designed for installation in places where it is necessary to ensure operation of devices under fire conditions. There are recommended for emergency lighting installations, smoke extraction systems, alarm systems, signalling systems, sound warning and control systems, fire alarm signaling and automation and other safety ensuring circuits.

CONSTRUCTION

conductor - bare copper, solid acc. to PN-EN 60228

insulation - cross-linked halogen free ceramic forming polymer compound

sheath - flame resistant, halogen free polymer compound

HDGs FE180/PH90/E90

CHARACTERISTICS

Conductor cross-section	
Number of conductors	Nominal conductor cross-section
n	mm ²
2 ÷ 5	1 ÷ 10
6 ÷ 37	1 ÷ 2,5

Operating voltage 300/500 V

Voltage test 2000 V, 50 Hz

core/core 2000 V, 50 Hz

core/screen 2000 V, 50 Hz

Insulation resistivity at 90 °C, minimum 10¹¹

Operating temperature range

during operation -25 °C up to +70 °C

during installation -10 °C up to +50 °C

Minimum bending radius 10 x D single core

D = outer diameter

Cable combustibility

Fire resistance E90

Combustibility tests PN-EN 50200, PN-EN 50226:2006 IEC 60332-3


Reference standards ZN-CB-03-2002



CABLES

HDGsekwf FE180/PH90/E90

FIRE RESISTANT HALOGEN FREE POWER AND CONTROL CABLE



APPLICATIONS

Halogen-free fire resistant cables are designed for installation in places where it is necessary to ensure operation of devices under fire conditions. There are recommended for emergency lighting installations, smoke extraction systems, alarm systems, signalling systems, sound warning and control systems, fire alarm signaling and automation and other safety ensuring circuits.

CONSTRUCTION

conductor - bare copper, solid acc. to PN-EN 60228

insulation - cross-linked halogen free ceramic forming polymer compound

wrapping - polyester tape

screen - static screen of plastic coated metal foil with tinned copper drain wire

sheath - flame resistant, halogen free polymer compound

HDGsekwf FE180/PH90/E90

CHARACTERISTICS

Conductor cross-section	
Number of conductors	Nominal conductor cross-section
n	mm ²
2 + 5	1 + 10
6 + 37	1 + 2,5

Operating voltage 300/500 V

Voltage test 2000 V, 50 Hz

core/core 2000 V, 50 Hz

core/screen 2000 V, 50 Hz

Insulation resistivity at 90°C,
minimum 10¹¹

Operating temperature range

during operation -25°C up to +70°C

during installation -10°C up to +50°C

Minimum bending radius 10 x D single core
D = outer diameter

Cable combustibility

Fire resistance E90

Combustibility tests PN-EN 50200, PN-EN 50226:2006
IEC 60332-3


Reference standards ZN-CB-03-2002



CABLES

HTKSH FE180/PH90/E90

FIRE RESISTANT HALOGEN FREE ELECTRONIC AND TELECOMMUNICATIONS CABLE



APPLICATIONS

Safety installations cables are used for the transmission signals and measuring data in control circuits, in locations where a particular protection against fire and fire damage for human life and equipment is necessary.

Installation cables are not admissible for power installation purposes and direct burial.

CONSTRUCTION

conductor - bare copper, solid acc. to PN-EN 60228

insulation - mica tape and halogen free forming polymer compound

sheath - flame resistant, halogen free polymer compound

HTKSH FE180/PH90/E90

CHARACTERISTICS

Conductor cross-section	
Number of conductors	Nominal conductor diameter
n	mm
1 x 2 x ... 20 x 2 x ...	0,8
1 x 2 x ... 10 x 2 x ...	1,0
1 x 2 x ... 10 x 2 x ...	1,4
1 x 2 x ... 10 x 2 x ...	1,8
1 x 2 x ... 10 x 2 x ...	2,3

Operating voltage 225V
Voltage test 1500 V, 50 Hz
core/core

Insulation resistivity at 90°C,
minimum 10¹¹

Operating temperature range
during operation -25°C up to +70°C
during installation -5°C up to +50°C
Minimum bending radius

10 x D single core
D = outer diameter

Cable combustibility

Fire resistance

Combustibility tests

Reference standards


E90
PN-EN 50200, PN-EN 50225:2006
IEC 60332-3
ZN-CB-25-2005



CABLES

HTKSHekw FE180/PH90/E90

FIRE RESISTANT HALOGEN FREE ELECTRONIC AND TELECOMMUNICATIONS CABLE



APPLICATIONS

Safety installations cables are used for the transmission signals and measuring data in control circuits, in locations where a particular protection against fire and fire damage for human life and equipment is necessary. Installation cables are not admissible for power installation purposes and direct burial.

CONSTRUCTION

conductor - bare copper, solid acc. to PN-EN 60228

insulation - mica tape and halogen free forming polymer compound

wrapping - polyester tape

screen - static screen of plastic coated metal foil with a solid, tinned drain wire

sheath - flame resistant, halogen free polymer compound

HTKSHekw FE180/PH90/E90

CHARACTERISTICS

Conductor cross-section	
Number of conductors	Nominal conductor diameter
n	mm
1 x 2 x 20 x 2 x	0,8
1 x 2 x 10 x 2 x	1,0
1 x 2 x 10 x 2 x	1,4
1 x 2 x 10 x 2 x	1,8
1 x 2 x 10 x 2 x	2,3

Operating voltage 225V

Voltage test 1500 V, 50 Hz

core/core 1500 V, 50 Hz

core/screen 1500 V, 50 Hz

Insulation resistivity at 90°C, minimum 10¹¹

Operating temperature range

during operation -25°C up to +70°C

during installation -5°C up to +50°C

Minimum bending radius 10 x D single core
D = outer diameter

Cable combustibility

Fire resistance E90

Combustibility tests PN-EN 50200, PN-EN 50226:2006
IEC 60332-3


Reference standards ZN-CB-25-2005



CABLES

JE-H(St)H MIKA FE180/E90

FIRE RESISTANT HALOGEN FREE ELECTRONIC AND TELECOMUNICATIONS CABLE



APPLICATIONS

Safety installations cables are used for the transmission of signals and measuring data in control circuits, in locations where a particular protection against fire and fire damage for human life and equipment is necessary.

Installation cables are not admissible for power installation purposes and direct burial.

CONSTRUCTION

conductor - bare copper, solid acc. to DIN VDE 0295

insulation - mica tape and cross-linked halogen free forming polymer compound acc. to DIN VDE 0207-23

wrapping - polyester and glass-fibre tape

screen - static screen of plastic coated metal foil with a solid, tinned drain wire

sheath - flame resistant, halogen free polymer compound acc. to DIN VDE 0207-5

JE-H(St)H MIKA FE180/E90

CHARACTERISTICS

Conductor diameter	
Number of conductors	Nominal conductor diameter
n	mm
1 x 2 x 80 x 2 x	0,8
1 x 2 x 80 x 2 x	1,0

Operating voltage 225V

Voltage test 500 V, 50 Hz
core/core 2000 V, 50 Hz
core/screen

Insulation resistivity at 90°C, minimum 10^{12}

Operating temperature range during operation during installation

-25°C up to +80°C
-5°C up to +50°C

Minimum bending radius

8 x D single core
D = outer diameter

Cable combustibility

Fire resistance

Combustibility tests

Reference standards

E90

PN-EN 50226:2006, IEC 60332-3

DIN VDE 0815



DRAWINGS

Nr	Nr Fires	Czas	Symbol kaba	Pozycja	Konstrukcja mocowania, odległość, obciążenie
1	46		(N)HXH 4x1,5RE FE180/E90 0,6/1kV	1	Korytko kablowe KGL/KGOL 300H60/... B-300 1.5 m /20kg/m / grubość blachy 0,7 mm Mocowanie : Wspornik WPC/WPCO1000, Wysięgnik WMC/WMCO400 , pręt gwintowany PG M10 za pomocą uchwytu USV/USOV
2			(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
3	45		(N)HXH 4x50RM FE180/E90 0,6/1kV		
4			(N)HXH 4x50RM FE180/E90 0,6/1kV		
5	70		HDGs 2x1,0 FE180/PH90/E90 300/500V		
6			HDGs 2x1,0 FE180/PH90/E90 300/500V		
7	44		(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV	2	Korytko kablowe KGL/KGOL 300H60/... B-300 1.5 m /20kg/m / grubość blachy 0,7 mm Mocowanie : Wspornik WPC/WPCO1000, Wysięgnik WMC/WMCO400 , pręt gwintowany PG M10 za pomocą uchwytu USV/USOV
8			(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		
9	43		(N)HXCH 4x50RM/25 FE180/E90 0,6/1kV		
10			(N)HXCH 4x50RM/25 FE180/E90 0,6/1kV		
11	69		HDGsekwf 2x1,0 FE180/PH90/E90 300/500V		
12			HDGsekwf 2x1,0 FE180/PH90/E90 300/500V		
13	42		NHXH 4x1,5RE FE180/E90 0,6/1kV	3	Korytko kablowe KGJ/KGOJ 400H60/... B-400 1.5 m /20kg/m / grubość blachy 0,9 mm Mocowanie : Wspornik WPC/WPCO1000, Wysięgnik WMC/WMCO400 , pręt gwintowany PG M10 za pomocą uchwytu USV/USOV
14			NHXH 4x1,5RE FE180/E90 0,6/1kV		
15	41		NHXH 4x50RM FE180/E90 0,6/1kV		
16			NHXH 4x50RM FE180/E90 0,6/1kV		
17	68		HTKSH 1x2x0,8 FE180/PH90/E90 225V		
18			HTKSH 1x2x0,8 FE180/PH90/E90 225V		
19	67		BiTflame AS 1x2x0,8 FE180/PH90/E90 225V		
20			BiTflame AS 1x2x0,8 FE180/PH90/E90 225V		
21	40		NHXCH 4x1,5RM/1,5 FE180/E90 0,6/1kV	4	Korytko kablowe KGJ/KGOJ 400H60/... B-400 1.5 m /20kg/m / grubość blachy 0,9 mm Mocowanie : Wspornik WPC/WPCO1000, Wysięgnik WMC/WMCO400 , pręt gwintowany PG M10 za pomocą uchwytu USV/USOV
22			NHXCH 4x1,5RM/1,5 FE180/E90 0,6/1kV		
23	39		NHXCH 4x50RM/25 FE180/E90 0,6/1kV		
24			NHXCH 4x50RM/25 FE180/E90 0,6/1kV		
25	66		HTKSHekw 1x2x0,8 FE180/PH90/E90 225V		
26			HTKSHekw 1x2x0,8 FE180/PH90/E90 225V		
27	65		BiTflame AS(St) 1x2x0,8 FE180/PH90/E90 225V		
28			BiTflame AS(St) 1x2x0,8 FE180/PH90/E90 225V		
29	31		(N)HXH 4x1,5RE FE180/E90 0,6/1kV	5	Korytko siatkowe KDS/ KDSO 400H60/... B-400 1.5 m /20kg/m / grubość drutu fi 4,5 mm Mocowanie : Ceownik CWP/CWOP40H40/05, pręt gwintowany PG M10. Wieszak trapezowy WT 120 + pręt gwintowany PG M8 mocowany do blachy trapezowej
30	30		(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
31	29		(N)HXH 4x50RM FE180/E90 0,6/1kV		
32	28		(N)HXH 4x50RM FE180/E90 0,6/1kV		
33	61B		HDGs 2x1,0 FE180/E90 300/500V		
34			HDGs 2x1,0 FE180/E90 300/500V		
35	61A		HDGsekwf 2x1,0 FE180/E90 300/500V		
36			HDGsekwf 2x1,0 FE180/E90 300/500V		



DRAWINGS

Nr	Nr Fires	Czas	Symbol kaba	Pozycja	Konstrukcja mocowania, odległość, obciążenie
37	27		NHXXH 4x1,5RE FE180/E90 0,6/1kV	6	Korytka siatkowe KDS/ KDSO 400H60/... B-400 1.5 m /20kg/m / grubość drutu fi 4,5 mm Mocowanie : Ceownik CWP/CWOP40H40/05, pręt gwintowany PG M10. Wieszak trapezowy WT 120 + pręt gwintowany PG M8 mocowany do blachy trapezowej
38	26		NHXXH 4x1,5RE FE180/E90 0,6/1kV		
39	25		NHXXH 4x50RM FE180/E90 0,6/1kV		
40	24		NHXXH 4x50RM FE180/E90 0,6/1kV		
41	60B		HTKSH 1x2x0,8 FE180/PH90/E90 225V		
42			HTKSH 1x2x0,8 FE180/PH90/E90 225V		
43	60A		HTKSHekw 1x2x0,8 FE180/PH90/E90 225V		
44			HTKSHekw 1x2x0,8 FE180/PH90/E90 225V		
45	23		NHXXH 4x1,5RE FE180/E90 0,6/1kV	7	Korytka kablowe KGL/KGOL 300H60/... B-300 1.5 m /20kg/m / grubość blachy 0,7 mm Mocowanie : Ceownik CWP/CWOP40H40/05, pręt gwintowany PG M10
46	22		NHXXH 4x1,5RE FE180/E90 0,6/1kV		
47	21		NHXXH 4x50RM FE180/E90 0,6/1kV		
48	20		NHXXH 4x50RM FE180/E90 0,6/1kV		
49	58		HTKSH 1x2x0,8 FE180/PH90/E90 225V		
50			HTKSH 1x2x0,8 FE180/PH90/E90 225V		
51	19		NHXXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV	8	Korytka kablowe KGL/KGOL 300H60/... B-300 1.5 m /20kg/m / grubość blachy 0,7 mm Mocowanie : Ceownik CWP/CWOP40H40/05, pręt gwintowany PG M10
52	18		NHXXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		
53	17		NHXXCH 4x50RM/25 FE180/E90 0,6/1kV		
54	16		NHXXCH 4x50RM/25 FE180/E90 0,6/1kV		
55	57		HTKSHekw 1x2x0,8 FE180/PH90/E90		
56			HTKSHekw 1x2x0,8 FE180/PH90/E90		
57	12		(N)HXXH 4x1,5RE FE180/E90 0,6/1kV	9	Korytka kablowe KGJ/KGOJ 400H60/... B-400 1.5 m /20kg/m / grubość blachy 0,9 mm Mocowanie : Ceownik CWP/CWOP40H40/05, pręt gwintowany PG M10
58	11		(N)HXXH 4x1,5RE FE180/E90 0,6/1kV		
59	14		(N)HXXH 4x50RM FE180/E90 0,6/1kV		
60	13		(N)HXXH 4x50RM FE180/E90 0,6/1kV		
61	54B		HDGs 2x1,0 FE180/PH90/E90 300/500V		
62			HDGs 2x1,0 FE180/PH90/E90 300/500V		
63	54A		BITflame S 2x1,0 FE180/PH90/E90 300/500V		
64			BITflame S 2x1,0 FE180/PH90/E90 300/500V		
65	10		(N)HXXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV	10	Korytka kablowe KGJ/KGOJ 400H60/... B-400 1.5 m /20kg/m / grubość blachy 0,9 mm Mocowanie : Ceownik CWP/CWOP40H40/05, pręt gwintowany PG M10
66	9		(N)HXXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		
67	8		(N)HXXCH 4x50RM/25 FE180/E90 0,6/1kV		
68	7		(N)HXXCH 4x50RM/25 FE180/E90 0,6/1kV		
69	53B		HDGsekwf 2x1,0 FE180/PH90/E90 300/500V		
70			HDGsekwf 2x1,0 FE180/PH90/E90 300/500V		
71	53A		BITflame S(St) 2x1,0 FE180/PH90/E90 300/500V		
72			BITflame S(St) 2x1,0 FE180/PH90/E90 300/500V		



DRAWINGS


Nr	Nr Fires	Czas	Symbol kaba	Pozycja	Konstrukcja mocowania, odległość, obciążenie
73	52A		HTKSHekw 1x2x0,8 FE180/PH90/E90 225V	11	Uchwyt kablowy UDF. Mocowanie do płyty gips karton co 600mm za pomocą kołka HM 5x37S
74			HTKSHekw 1x2x0,8 FE180/PH90/E90 225V		
75	52B		HDGsekWF 2x1,0 FE180/PH90/E90 300/500V		
76			HDGsekWF 2x1,0 FE180/PH90/E90 300/500V		
77	6		(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
78	5		(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
79	4		(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		
80	3		(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		
81	2		(N)HXH 4x50RM FE180/E90 0,6/1kV		
82	1		(N)HXH 4x50RM FE180/E90 0,6/1kV		
83	72		HTKSH 1x2x0,8 FE180/E90 225V	12	Obejma kablowa KSA Mocowanie co 300mm + puszkę PMO1
84	38		(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
85	71		JE-H(St)H 2x2x0,8 FE180/E90 225V		
86	37		(N)HXH 4x6RE FE180/E90 0,6/1kV		
87	36		(N)HXH 4x6RE FE180/E90 0,6/1kV	13	Obejma kablowa KSA Mocowanie co 300mm + puszkę PMO2
88	56		HTKSH 1x2x0,8 FE180/E90 225V		
89	15		(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
90	55		JE-H(St)H 2x2x0,8 FE180/E90 225V		
91	35		(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV	14	Korytka siatkowe KDS/ KDSO 60H60/... B-60 1.5 m /2kg/m / grubość drutu fi 4,5 mm Mocowanie : WKS60, pręt gwintowany PG M6. Wieszak trapezowy WT 120 + pręt gwintowany PG M6 mocowany do blachy trapezowej
92	34		(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		
93	33		(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
94	32		(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
95	64		HDGs 2x1,0 FE180/PH90/E90 300/500V		
96			HDGs 2x1,0 FE180/PH90/E90 300/500V		
97	63		HTKSH 1x2x0,8 FE180/PH90/E90 225V		
98			HTKSH 1x2x0,8 FE180/PH90/E90 225V		
99	62		HDGsekWF 2x1,0 FE180/PH90/E90 300/500V		
100			HDGsekWF 2x1,0 FE180/PH90/E90 300/500V		
101	74		HTKSH 1x2x0,8 FE180/PH90/E90 225V	15	Uchwyt kablowy UDF. Mocowanie do Ytonga co 600mm za pomocą kołka FMD 6x32
102			HTKSH 1x2x0,8 FE180/PH90/E90 225V		
103	73		HDGs 2x1,0 FE180/PH90/E90 300/500V		
104			HDGs 2x1,0 FE180/PH90/E90 300/500V		
105	50		(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
106			(N)HXH 4x1,5RE FE180/E90 0,6/1kV		
107	49		(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		
108			(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV		
109	48		(N)HXH 4x50RM FE180/E90 0,6/1kV		Uchwyt kablowy UDF. Mocowanie do Ytonga co 600mm za pomocą kołka FMD 6x40
110			(N)HXH 4x50RM FE180/E90 0,6/1kV		
111	47		(N)HXCH 4x50RM/25 FE180/E90 0,6/1kV		
112			(N)HXCH 4x50RM/25 FE180/E90 0,6/1kV		




DRAWINGS

Nr	Nr Fires	Czas	Symbol kaba	Pozycja	Konstrukcja mocowania, odległość, obciążenie
113	59B		HTKSH 1x2x0,8 FE180/PH90/E90 225V – test	16	Uchwyt kablowy UDF. Mocowanie co 600mm
114			HTKSH 1x2x0,8 FE180/PH90/E90 225V – test		
115	59A		HDGs 2x1,0 FE180/PH90/E90 300/500V – test		
116			HDGs 2x1,0 FE180/PH90/E90 300/500V – test		


Lp.	Symbol kabla	Ilość [szt.]	Średnica [mm]	Ciężar kabla [kg/m]
1	NHXX 4x1,5RE FE180/E90 0,6/1kV	6	14,9	0,31
2	NHXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV	4	15,7	0,35
3	NHXX 4x50RM FE180/E90 0,6/1kV	6	36,9	3,05
4	NHXCH 4x50RM/25 FE180/E90 0,6/1kV	4	39,8	3,30
5	(N)HXX 4x1,5RE FE180/E90 0,6/1kV	14	13,1	0,24
6	(N)HXCH 4x1,5RE/1,5 FE180/E90 0,6/1kV	10	14,7	0,30
7	(N)HXX 4x50RM FE180/E90 0,6/1kV	10	34,9	2,85
8	(N)HXCH 4x50RM/25 FE180/E90 0,6/1kV	6	36,9	3,10
9	(N)HXX 4x6RE FE180/E90 0,6/1kV	2	17,9	0,55
10	HTKSH 1x2x0,8 FE180/PH90/E90 225V	14	6,1	0,04
11	HTKSHekw 1x2x0,8 FE180/PH90/E90 225V	8	7,4	0,06
12	HDGs 2x1,0 FE180/PH90/E90 300/500V	12	6,8	0,06
13	HDGsekwf 2x1,0 FE180/PH90/E90 300/500V	10	7,1	0,07
14	BiTflame AS 1x2x0,8 FE180/PH90/E90 225V	2	6,1	0,04
15	BiTflame AS(St) 1x2x0,8 FE180/PH90/E90 225V	2	7,4	0,06
16	BiTflame S 2x1,0 FE180/PH90/E90 300/500V	2	6,8	0,06
17	BiTflame S(St) 2x1,0 FE180/PH90/E90 300/500V	2	7,1	0,07
18	JE-H(St)H 2x2x0,8 FE180/E90	2	9,5	0,09








DRAWINGS






DRAWINGS






DRAWINGS






D-D



BAKS- BITNER 2013.02.28




E-E



BAKS- BITNER 2013.02.28




F-F




BAKS- BITNER 2013.02.28




G-G




BAKS- BITNER 2013.02.28






BAKS- BITNER 2013.02.28






K-K



BAKS- BITNER 2013.02.28




DRAWINGS



12	Śruba z łbem grzybkowym	SGKM6x12	12
11	Śruba z łbem grzybkowym	SGKM8x14	4
10	Śruba	SMM10x30	4
9	Podkładka	PP10	6
8	Nakrętka	NSM10	6
7	Śruba tulejowa rozporowa	PSROM10x80	3
6	Uchwyt	UPWO	2
5	Uchwyt sufitowy	USV/USOV	1
4	Pręt gwintowany	PGM10/...	1
3	Korytko	KGL/KGOL300H60	2
2	Wysięgnik	WMC/WMCO300	2
1	Wspornik sufitowy	WPCW/WPCO1000	1
L.p.	Nazwa	Symbol	Szt.




DRAWINGS



12	Śruba z łbem grzybkowym	SGKM6x12	12
11	Śruba z łbem grzybkowym	SGKM8x14	4
10	Śruba	SMM10x30	4
9	Podkładka	PP10	6
8	Nakrętka	NSM10	6
7	Śruba tulejowa rozporowa	PSROM10x80	3
6	Uchwyt	UPWO	2
5	Uchwyt sufitowy	USV/USOV	1
4	Pręt gwintowany	PGM10/...	1
3	Korytka	KGJ/KGOJ400H60	2
2	Wysięgnik	WMC/WMCO400	2
1	Wspornik sufitowy	WPCW/WPCO1000	1
L.p.	Nazwa	Symbol	Szt.




DRAWINGS



11	Zacisk śrubowy	ZS/ZSO	2
10	Uchwyt śrubowy	USS/USS	5
9	Podkładka	PP8	4
8	Nakrętka	NSM8	4
7	Pręt gwintowany	PGM8/....	2
6	Podkładka	PP10	8
5	Nakrętka	NSM10	8
4	Wieszak trapezowy	WT/WT0120Ø11	2
3	Pręt gwintowany	PGM10/....	2
2	Ceownik wzmacniony	CWP/CWOP40H40/05	1
1	Korytko siatkowe	KDS/KDSO400H60	1
L.p.	Nazwa	Symbol	Szt.




DRAWINGS



7	Podkładka	PP10	8
6	Nakrętka	NSM10	8
5	Śruba z łbem grzybkowym	SGKM6x12	12
4	Korytko	KGL/KGOL300H60	2
3	Tuleja rozporowa stalowa	TRSOM10	2
2	Pręt gwintowany	PGM10/...	2
1	Ceownik wzmacniony	CWP/CWOP40H40/04	2
L.p.	Nazwa	Symbol	Szt.




DRAWINGS





Blacha trapezowa





10	Podkładka	PP6	2
9	Nakrętka	NSM6	2
8	Pręt gwintowany	PGM6/...	1
7	Korytka siatkowe	KDS/KDSO60H60/3	1
6	Uchwyt śrubowy	USSN/USSO	2
5	Wieszak	WKS/WKSO60	1
4	Nakrętka	NSM6	2
3	Podkładka	PP6	2
2	Pręt gwintowany	PGM6/...	1
1	Tuleja rozporowa stalowa	TRSOM6	1
L.p.	Nazwa	Symbol	Szt.

FIRES 064/S-22/03/2012-E

DRAWINGS

Poz.1		Poz.2
A	Typ	Ilość
100	KGL/KGDL100H60/3	6
200	KGL/KGDL200H60/3	7
300	KGL/KGDL300H60/3	8



2	Śruba z łbem grzybkowym	SGN M6x12		8		
1	Korytka	KGL /KGDL300H60/3		2		
Lp.	Nazwa	Symbol	Materiał	Szt.	Nr katalogowy	
	Długość wykonania ręcznie		Główny:	Masa Bqg	Kodarka	
			Wzrost: Nr normy podłogi (z normy)			
Projektant	Nazwa	Firma	Data	Połączenie KGL /KGDL300H60/3		
Wykonanie						
Sprawdzenie						
Zatwierdzenie						
				Nr programu rozrywania	Nr rysunku	



DRAWINGS

Poz.1		Poz.2
A	Typ	Ilość
100	KGL/KGDL100H60/3	6
200	KGL/KGDL200H60/3	7
300	KGL/KGDL300H60/3	8




2	Śruba z łbem przylbkowym	SS316 M6x12		8	
1	Korytko	KGL/KGDL300H60/3		2	
Lp.	Nazwa	Symbol	Materiał	Szt.	Nr katalogowy
	Długość wytworzonego niezłomowanego		Główny Nr normy podfabrykat (nr normy)	Masa Bkg	Podziałka
Projektant					Format A4
Wykonanie					Arkusz 1
Sprzedaż					Arkusz 1
Zatwierdzenie					
				Potaczenie KGL/KGDL300H60/3	
				Nr programu kosztowniczego	Nr zleceń
				Nr rysunku	

FIRES 064/S-22/03/2012-E




KDS/KDS□...H60/3

Typ	Szerokość A(mm)	Długość L(mm)
KGJ/KGDJ100H60/3	100	3000
KGJ/KGDJ200H60/3	200	3000
KGJ/KGDJ300H60/3	300	3000
KGJ/KGDJ400H60/3	400	3000




	Długość wykładni metrowych		Materiał		Masa Dłg 1:5	Format A4	
			Gotunki			Arkusz	
			Nr normy			Arkuszy	
			półfabrykat (nr normy)				
Projektant	Nazwa	Prosta	Data	Nazwa rysunku			
Rysował				KGJ/KGDJ...H60/3			
Sprawił							
Zatwierdził							
Profesjonalne Systemy Tras Kablowych			Nr programu maszynowego		Nr zębiny		
			Nr rysunku				

DRAWINGS




DRAWINGS



20	Uchwyt kabla	UDF 43	405543	21,5	60,0	20,0	2,0
19	Uchwyt kabla	UDF 40	405540	20,0	57,0	20,0	2,0
18	Uchwyt kabla	UDF 37	405537	18,5	54,0	20,0	2,0
17	Uchwyt kabla	UDF 34	405534	17,0	51,0	20,0	2,0
16	Uchwyt kabla	UDF 31	405531	15,5	48,0	20,0	2,0
15	Uchwyt kabla	UDF 28	405528	14,0	45,0	20,0	2,0
14	Uchwyt kabla	UDF 25	405525	12,5	44,0	20,0	2,0
13	Uchwyt kabla	UDF 22	405522	11,0	41,0	14,0	2,0
12	Uchwyt kabla	UDF 20	405520	10,0	39,0	14,0	2,0
11	Uchwyt kabla	UDF 18	405518	9,0	37,0	14,0	2,0
10	Uchwyt kabla	UDF 16	405516	8,0	35,0	14,0	2,0
9	Uchwyt kabla	UDF 15	405515	7,5	34,0	14,0	2,0
8	Uchwyt kabla	UDF 14	405514	7,0	33,0	14,0	1,2
7	Uchwyt kabla	UDF 12	405512	6,0	30,0	14,0	1,2
6	Uchwyt kabla	UDF 10	405510	5,0	28,0	14,0	1,2
5	Uchwyt kabla	UDF 9	405509	4,5	27,0	14,0	1,2
4	Uchwyt kabla	UDF 8	405508	4,0	26,0	14,0	1,2
3	Uchwyt kabla	UDF 7	405507	3,5	25,0	14,0	1,2
2	Uchwyt kabla	UDF 6	405506	3,0	24,0	14,0	1,2
1	Uchwyt kabla	UDF 5	405505	2,5	23,0	14,0	1,2
LP	Nazwa wyrobu	Symbol	Nr Katalogowy	R [mm]	L [mm]	H [mm]	G [mm]

	Długość wymiaru niezależnych	$\pm 0,5$	Gatunek Nr normy podstawy (nr normy)	Masa (kg) ---	Podziałka 1:1	Format A4 Arkusz --- Arkuszy ---
Projektant	Jacek Gruchowski	Data 20.10.05 20.02.08 20.02.08 20.02.08	Nazwa rysunku UDF 5-43			
Wykonawca	Jakub Rudnik		Nr rysunku 4055.....			
Sprawdzający	Jacek Kilczek					
Zatwierdzający	Jacek Kilczek					
Profesjonalne Systemy Tras Kablowych			Nr zmiany			

DRAWINGS



symbol	A	B	C	D
KSA 6	5	9	11	12
KSA 8	7	15	11	12
KSA 10	9	17	11	12
KSA 12	11	19	11	12
KSA 14	13	22	11	12
KSA 16	15	24	11	12
KSA 18	17	26	11	12
KSA 20	19	27	11	12
KSA 22	21	29	11	14
KSA 24	23	31	11	14
KSA 25	24	32	11	14
KSA 26	25	33	11	14
KSA 28	27	35	11	14
KSA 32	31	39	11	14
KSA 33	32	40	12	16
KSA 35	34	42	12	16
KSA 36	35	45	12	16
KSA 40	39	47	12	16
KSA 42	41	49	12	16
KSA 48	46	56	14	16
KSA 50	48	58	14	16
KSA 55	53	62	14	16

		Odchylka wyników metrolowanych	Materiał	Getunek	Masa [kg]	Podziałka	Format A4
				Nr normy			
Projektował	J. GROCHOWSKI	Podpis	Data	Nazwa rysunku	KSA		
Rysował	J. GROCHOWSKI	Podpis	Data	Nr rysunku			
Sprawdził	T. WŁODARCZYK	Podpis	Data	Nr rysunku	---		
Zatwierdził	J. KŁOCZEK	Podpis	Data	Nr rysunku			
Profesjonalne Systemy Tras Kablowych				---			Nr zbilans

#	Symbol	b	l	Śr. otwór
1	UKZ/UKZ ¹ /16-22	22mm	61,5mm	M8x40
2	UKZ/UKZ ¹ /22-28	28mm	68mm	M8x40
3	UKZ/UKZ ¹ /28-34	34mm	76mm	M8x40
4	UKZ/UKZ ¹ /34-40	40mm	84,5mm	M8x40
5	UKZ/UKZ ¹ /40-46	46mm	91,5mm	M8x50
6	UKZ/UKZ ¹ /46-52	52mm	102mm	M8x50
7	UKZ/UKZ ¹ /52-64	64mm	111mm	M8x50

Legenda:

1. Układowy symbol

2. Układowy symbol

3. Układowy symbol

4. Układowy symbol

5. Układowy symbol

6. Układowy symbol

7. Układowy symbol

UKZ/UKZ¹

UKZ/UKZ¹/16-22

UKZ/UKZ¹/22-28

UKZ/UKZ¹/28-34

UKZ/UKZ¹/34-40


UKZ/UKZ¹/40-46

UKZ/UKZ¹/46-52

UKZ/UKZ¹/52-64




DRAWINGS



	Długość wykładnia niezależnych		Lobunek		Masa (kg)	Podobnie	Format A4
			Nr normy				
			półfabrykat (nr normy)			2:1	Arkusz 1
Projektant	Nazwisko	M. Sobolewski	Podpis	Data	Nazwa rysunku		
Rysował					USSN/USSD		
Sprawił					Nr programu maszynowego		
Zatwierdził					Nr rysunku		
 Profesjonalne Systemy Tras Kablowych						Nr zębny	

DRAWINGS



	Odczytywanie wymiarów i tolerancji		Materiał	Główny		Masa [kg]	Początek	Forma	A4	
				Nr normy						POLSKA NORMA
				polityka (z normy)						
Projektant	Nazwa	P. OROKOWSKI	Projekt	Data	Nazwa rysunku					
Rysownik					WKSO60					
Sprawdził										
Zatwierdził					Nr programu maszynowego					
					Nr rysunku					
Profesjonalne Systemy Tras Kablowych										

Technical drawing of a mechanical part, showing a side view and a cross-section.

Side View (Top):

- Overall length: 20
- Flange thickness: 2
- Flange outer diameter: 12
- Flange inner diameter: 10
- Flange hole diameter: 8
- Flange hole pitch: F14
- Flange hole offset: 9


Cross-section (Bottom):


- Angle between arms: 95°
- Arm length: 96
- Arm width: 23

[illegible]



DRAWINGS





7	Ceramik sznorkienny	CWP/CWDP40H40/ 2		P000	3,50
6	Ceramik sznorkienny	CWP/CWDP40H40/07		700	1,23
5	Ceramik sznorkienny	CWP/CWDP40H40/06		600	1,05
4	Ceramik sznorkienny	CWP/CWDP40H40/05		500	0,88
3	Ceramik sznorkienny	CWP/CWDP40H40/04		400	0,70
2	Ceramik sznorkienny	CWP/CWDP40H40/03		300	0,53
1	Ceramik sznorkienny	CWP/CWDP40H40/02		200	0,35

LP Nazwa wyrobu		Symbol	Mtr. Kategoria	L (mm)	Masa (kg)
Grubość cwi					
15					
Materiał		Blacha stal. cynk. nat. Szalowana			
N. normy		PN-EN 1632/2005			
podstawy (w normy)		----			
Masa (kg)					
Podobieństwo					
Formet		A4			
Analog		----			
Analog					

Projektant	Jacek Szankowski
Konstruktor	Jacek Szankowski
Wykonawca	Jacek Szankowski
Wzrost	Jacek Szankowski




Profesjonalne Systemy
Troski Kwalifikacji

In. rysunku

CWP/CWDP40H40/...

In. rysunku



DRAWINGS

System E-30, E-90 - Puszki łączeniowo-rozgałęźne



Puszka łączeniowo-rozgałęźna



PMO1 (5/6)



PMO1 (5/3)



PMO1 (3/3)



PMO1

SYMBOL	nr katalogowy	il.
PMO1(5/6)	801100	1
PMO1(5/3)	801200	1
PMO1(3/3)	801300	1

PMO1 E

PMO1(5/6) E	801101	1
PMO1(5/3) E	801201	1
PMO1(3/3) E	801301	1

INFORMACJA TECHNICZNA

Stosowana jako puszka:

- przelotowa o przekroju kabla od 0,5 mm² do 6 mm²,
- rozgałęźna o przekroju kabla od 0,5 mm² do 1,5 mm².


Puszka wykonywana jest w wersji:

- PMO1 5/6 - 5 kostek zaciskowych, 6 dławików gumowych
- PMO1 5/3 - 5 kostek zaciskowych, 3 dławiki gumowe
- PMO1 3/3 - 3 kostki zaciskowe, 3 dławiki gumowe
- PMO1 5/6 E - 5 kostek zaciskowych, 6 dławików gumowych
- PMO1 5/3 E - 5 kostek zaciskowych, 3 dławiki gumowe
- PMO1 3/3 E - 3 kostki zaciskowe, 3 dławiki gumowe


Maksymalne przekroje żył i ich ilość mieszcząca się w gnieździe kostki:

5 x 0,5 mm ²	1 x 2,5 mm ²
5 x 0,75 mm ²	1 x 4 mm ²
4 x 1 mm ²	1 x 6 mm ²
3 x 1,5 mm ²	

PMO1 (5/6)




PMO1 (5/3) | PMO1 (3/3)



ZASTOSOWANIE

Puszka łączeniowa i rozgałęźna, UI=400 V, z trwałym zachowaniem funkcji łączenia E30 / E60 / E90 wg DIN 4102 część 12. Stopień ochrony IP54, zakres uszczelnienia od 7 mm do 18,5 mm. Mocowanie poprzez zewnętrzne uchwyty montażowe: do betonu za pomocą kołków stalowych SR06x30, do drabinek i korytek kablowych za pomocą śruby SGKM6x12.

Puszka łączeniowo-rozgałęźna



PMO2 (5/6)



PMO2 (5/3)



PMO2 (3/3)



PMO2

SYMBOL	nr katalogowy	il.
PMO2(5/6)	802010	1
PMO2(5/3)	802020	1
PMO2(3/3)	802030	1

PMO2 E

PMO2(5/6) E	802011	1
PMO2(5/3) E	802021	1
PMO2(3/3) E	802031	1

INFORMACJA TECHNICZNA

Stosowana jako puszka:

- przelotowa o przekroju kabla od 1,0 mm² do 10 mm²,
- rozgałęźna o przekroju kabla od 1,0 mm² do 4 mm².


Puszka wykonywana jest w wersji:

- PMO2 5/6 - 5 kostek zaciskowych, 6 dławików gumowych
- PMO2 5/3 - 5 kostek zaciskowych, 3 dławiki gumowe
- PMO2 3/3 - 3 kostki zaciskowe, 3 dławiki gumowe
- PMO2 5/6 E - 5 kostek zaciskowych, 6 dławików gumowych
- PMO2 5/3 E - 5 kostek zaciskowych, 3 dławiki gumowe
- PMO2 3/3 E - 3 kostki zaciskowe, 3 dławiki gumowe



Maksymalne przekroje żył i ich ilość mieszcząca się w gnieździe kostki:

6 x 1 mm ²	2 x 4 mm ²
6 x 1,5 mm ²	1 x 6 mm ²
4 x 2,5 mm ²	1 x 10 mm ²

PMO2 (5/6)



PMO2 (5/3) | PMO2 (3/3)



ZASTOSOWANIE

Puszka łączeniowa i rozgałęźna, UI=400 V, z trwałym zachowaniem funkcji łączenia E30 / E60 / E90 wg DIN 4102 część 12. Stopień ochrony IP54, zakres uszczelnienia od 11 mm do 24 mm. Mocowanie poprzez zewnętrzne uchwyty montażowe: do betonu za pomocą kołków stalowych SR06x30, do drabinek i korytek kablowych za pomocą śruby SGKM6x12.

MATERIAL

PMO1, PMO2, - blacha stalowa, malowana proszkowo RAL 2003
PMO1 E, PMO2 E, - blacha kwasoodporna, 1.4301 malowana proszkowo RAL 2003
Kostka zaciskowa wykonana jest ze specjalnej ceramiki odpornej na wysokie temperatury, dławik wykonany jest z tworzywa bezhalogenowego mocowanie poprzez zewnętrzne uchwyty montażowe



7. FINAL PROVISION

- § This report details the method of construction, the test conditions and results obtained when the specific element of construction described herein was following the procedure outlined in STN EN 1363-1, and where appropriate STN 92 0205:2012. Any significant deviation with respect to size, constructional details, loads, stresses, edge or end conditions other than those allowed under the field of direct application in the relevant test method is not covered by this report.
- § Because of the nature of the fire resistance testing and consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.
- § The test results refer only to the tested subjects. This test report is not an approval of the tested product by the test laboratory or the accreditation body overseeing the laboratory's activities. The test was carried out on testing equipment that is the property of FIRES, s.r.o., Batizovce. Without the written permission of the test laboratory this test report may be copied and/or distributed only as the whole. Any modifications of the test report can be made only by the fire resistance test laboratory FIRES, s.r.o., Batizovce.

Approved by:

Ing. Štefan Rástocký
leader of the testing laboratory



Prepared by:

Bc. Dávid Šubert
technician of the testing laboratory

8. NORMATIVE REFERENCES

STN EN 1363-1: 2001	Fire resistance tests. Part 1: General requirements
STN 92 0205:2012	Fire behaviour of construction products and building constructions. Circuit integrity maintenance of cable systems. Requirements, testing and classification.
DIN 4102 – 2:1977-09	Fire behaviour of building materials and elements - requirements and testing
DIN 4102 – 12:1998-11	Fire resistance of electric cable systems required to maintain circuit integrity
ZP-27/2008 PAVUS	Test method for determination of functionality class of cables and cable loadbearing constructions - cable circuits in case of fire

THE END OF THE TEST REPORT